

	Refrigerant Unit	Freezer Unit			
Data Running as is...					
Kw/h Meters Installed	24/08/16	24/08/16			
Days monitored	51	28			
Total Kw/h used	718.97	1668.63			
Kw/h per Day	14.10	59.59			
Invisaflects Applied Data					
Applied Date	n/a	22/09/16			
Days monitored	n/a	22			
Total Kw/h used	n/a	1054.64			
Kw/h per Day	n/a	47.94			
Kw/h Used Decrease	n/a	19.56%			
Bluemaxx Installed Data					
Applied Date	14/10/16	14/10/16			
Days Monitored	17	17			
Total Kw/h used	217.12	710.23			
Kw/h per Day	12.77	41.78			
Kw/h Used Decrease	9.40%	29.90%			
Kw/h Decrease between Invisaflects & Bluemaxx	n/a	12.85%			
Total Kw/h Decrease	9.40%	24.73%			
Raw Data Used					
	Refrigerant Unit				
Meters Installed	24/08/16				
First Meter Reading Date	14/10/16				
Meter Reading	718.97				
Total Days Metered	51				
bluemaxx installed	14/10/16		Weather		

Last Meter Reading Date	31/10/16			Temp	Dew
Meter Reading	936.06		24/8-22/9	14 mean avg	11 avg
Total Days Metered	17		22/9 - 14/10	10 mean avg	7 avg
			14/10 - 31/10	8 mean avg	7 avg
	Freezer Unit				
Meters Installed	24/08/16				
First Meter Reading Date	22/09/16				
Meter Reading	1668.63				
Total Days Metered	28				
Invisaflects installed	22/09/16				
Last Reading Date for Invisaflect	14/10/16				
Meter Reading	2723.27				
Days Monitored	22				
bluemaxx installed	14/10/16				
Last Reading Date for bluemaxx	31/10/16				
Meter Reading	3433.5				
Days Monitored	17				